


Project: Plant Ground Support Equipment - Scope & Goal

- Starpath's Plant... in Space
- Goal: Enable the Plant to be tested on Earth in an analogous Lunar environment



- Allocated Budget: \$75k, Timeline: 3.5 mo.

Defining Requirements

- Cooling Requirements
 - To accommodate the 3 Plant Subsystems, as a stand-in for Space Radiator
 - Extraction: 5kW <50C
 - Conversion: 30kW <50C
 - Liquefaction: 3.3kW <0C
- Vacuum Requirements
 - Performance of valves proportional to pressure difference
 - 0.12 mol/s H₂ leak rate = 5.7CFM
 - >leak rate + margin for quick pump down time
- Power Requirements
 - PEM Stack (electrolyzer, conversion): 60kW 200VDC
 - Other electronics: 10kW 120VDC
- Skid Requirements
 - Safely contain Cooling, Vacuum Subsystems
 - Transportable to Plant Test location
 - Aesthetically appealing for external stakeholder demo

Requirements

System	Plant 2
Subsystem	Ground Support Equipment
RE	Conor Zachar
Updated	11/7/2024

Requirements ▾




#	Number	Category	Statement	Source
	0	systems	Subsystem shall supply 60kW @ 200VDC and 10kW @ 120VDC to Box 1	czachar
	1	systems	Subsystem shall supply a minimum of 35kW of cooling power <50C and 3.3kW <0C	czachar
	2	systems	Subsystem shall supply a near-vacuum of <0.01bar and pump at least 10CFM	czachar
	3	build	Subsystem shall cost less than \$75,000 in hardare/operational expenses	allocated, sys.12
	4	environmental	Subsystem shall be transportable to/from test location	czachar
	5	systems	Subsystem shall be of an appearance to inspire the public	flowed down, sys.10
	6	systems	Subsystem shall not interfere with Rover or Tower installations	flowed down, sys.4
	7	build	Subsystem shall complete testing on/before December 20, 2024	derived, sys.11


Skid - Concept Selection

- Size
 - Footprint driven by cooling loop size, 3-4 m²
- Material
 - Criteria: cost, manufacturability, strength, safety, aesthetics
 - Chosen Material
 - Al 6061 (σ_y : 276 MPa (T6), 76 MPa (O), ρ : 2.70 g/cm³)
 - Advantages: cost, easy MIG weld, FEA indicates sufficient strength, nonflammable, good aesthetics
 - Drawbacks: warping while welding, see setup
 - Considered
 - Wood: (MOR: 40MPa, ρ : 0.6 g/cm³)
 - lowest cost, weight, but lacking in strength, flammable, aesthetic concerns
 - Low Carbon Steel (σ_y : 250MPa, ρ : 7.9 g/cm³)
 - higher strength but heavier, requires finishing (corrosion), challenges welding
- Concept
 - Chosen Concept
 - Welded skid & frame: in-house manufacturing saves cost, compact & customizable form factor
 - Considered
 - Trailer: enables on-road transportation* but adds cost, bulkier less efficient footprint

*Deleted requirement, unnecessary as complete build & test of the Plant to be done at Starpath HQ. Instead, pallet jack/forklift compatibility incorporated into design



Trailer: evaluated concept





Skid: chosen concept



Skid - Detailed Design

- 6' x 6' to accommodate cooling loop, vacuum line
- Pallet jack compatible
- Aluminum 6061
- FEA: Fixed @ Forklift Mounts, 4000N downward force applied across platform

B: Static Structural
Equivalent Stress
Type: Equivalent (von-Mises) Stress
Unit: MPa
Time: 1 s
11/5/2024 5:28 PM



B: Static Structural
Equivalent Elastic Strain
Type: Equivalent Elastic Strain
Unit: mm/mm
Time: 1 s
11/5/2024 5:31 PM



Material Properties	6061-T6	6061-O
Yield Strength (FOS)	276 MPa (14.2)	76MPa (3.9)
UTS (FOS)	310 MPa (16.0)	130 MPa (6.7)
Fracture strain (FOS)	0.08 (284.7)	0.20 (711.9)

Skid - Build

- Materials
 - Thickness selected for strength & ease of weld
 - 4x 36"x36"x1/4" plates
 - 1/8" rectangular tubing
- MIG Welded
- Aluminum perforated sheets + self-tapping screws



Full skid w/ perforated sheet enclosure




Welded frame



Weld setup: Bottom view

Cooling - Concept Selection


- Heat capacity & temperature requirements
 - Conversion + Extraction: 35kw <50C
 - Liquefaction: 3.3kW <0C
- Design decision: separate 2x cooling loops
 - Provide high heat capacity cooling at a higher temp for conversion & extraction
 - Lower heat capacity, lower temp for liquefaction cooling
- Conversion & Extraction Loop
 - Concept selected: Air-to-water heat exchangers
 - Use ambient air temp to cool below 50C
 - Low cost, low complexity, reliable
 - Considered: Heat Pump
 - Not selected due to higher cost & complexity
- Liquefaction Loop
 - Concept selected: Low Temp chiller
 - Found off-the-shelf within spec, reliable & customizable cooling
 - Evaluated: Immersion cooling
 - Copper pipes + ice bath
 - Not feasible due to test length requirements



Ambient Temp Cooling - Design Details

Requirement: 35kW cooling, ~100C -> <50C

- Air-To-Liquid HEX in Series
 - Spec'ed for heat capacity, dT, see subscale test
 - Coolant pumps in series to offset head loss
- Plate HEX
 - Compact, efficient
- Sensing: calculate $Q^* = m^* c \Delta T$
 - K Type Thermocouples, breakout boards
 - Optimal within 0-100C range
 - 10V Flowmeter
 - Voltage compatible w/ Arduino (for test) & Plant brain




Max Cooling needed		3x 20"x20" HEX	
Water T _{hot} (plant)	373 K	V*	3 GPM
Water T _{cool} (plant)	323 K	V*	0.000189270589 m ³ /s
cp water	4.186 kJ/kgK	d_pipes	0.00953 m
mass flow rate	0.15 kg/s	A_pipes	0.000071 m ²
Required Q _{lost} , plant	31.395 kW	v_h20	2.65622 m/s
Temp change of working fluid		# pipes/row	3
cp working fluid (water)	4.186 kJ/kgK	rows	20
V* working fluid	3 gal/min	# HEX	3
V* working fluid	11.34 l/min	l_row	0.5588 m
m* working fluid	0.189 kg/s	l_pipes	100.584 m
Plate HEX efficiency	0.90	friction factor	0.0200
dT required, working fluid	44.09 K	p_h20	1000.00 kg/m ³
		ΔP	745.0599518 kPa
		ΔP	249.3 ft head

Ambient Temp Cooling - Build

Requirement: 35kW cooling, $\sim 100^{\circ}\text{C} \rightarrow < 50^{\circ}\text{C}$

- Subscale test
 - Boiler tank
 - 15gal Tank + 2x 5kW heating elements
 - Heating could not be scaled further due to power constraints at the time, safety considerations (arcing @ high current, gap between conductors)
 - Setup with 1x HEX
 - Indicated HEX cools @ approx 50% of nominal capacity, $95^{\circ}\text{C} \rightarrow 50-60^{\circ}\text{C}$
 - Decision for 3x in series: anticipating decrease in efficiency but increase in dT
- Build
 - 3x 40kW HEX in series
 - NPT fittings & liquid hydraulic thread sealant to prevent leaks



Full test setup



Subscale test setup

Max Sustainable Q*		
V_boilertank	15	gal
V_boilertank	56.781	L
Tmax	100	C
Tfinal	30	C
c_H2O	4.187	kJ/kgC
Qmax	16641.99	kJ
t_test	0.2	hr
Q*_heaters	10	kW
Q*max sustained	33.11	kW

Test limitations

Ambient Temp Cooling - Test


Requirement: 35kW cooling, $\sim 100^{\circ}\text{C} \rightarrow < 50^{\circ}\text{C}$

- 40 kW peak
- Performs best at higher dT
 - Planned plant input of 100°C is ideal
 - Test limitation: setup can only heat at 10kW, max
- T_{cool} Maintained $< 40^{\circ}\text{C}$




Cooling loop

Skid Test, 12/19



Cooling capacity of cooling loop



Arduino & perfboard for data collection

Low Temp Cooling - Initial Design

Requirement: 3.3kW cooling, <0C

- Initial Design: Immersion Chilling
 - 30m copper tubing
 - Saltwater ice bath
- System wide requirements changed: 3hr test to 15hr
 - Deemed infeasible due to volume of ice required
 - Hand calcs: Lf ice not suitable for 45kWh
 - LN2- lower temps easily achievable, but mass not feasible

Variable	value	unit
Copper Tubes		
HEX_e	0.8	
V*	3	GPM
m*	0.1892705	kg/s
Q*	3.75	kW
c_h20	4.184	kJ/KgK
dT_h20	4.73539992	K
Tcold_pipes	270	K
Thot_pipes	274.7353999	K
Tbath	270	K
dT_m	2.36769996	K
U_copper	2	kW/m2K
A_req	0.791907772	m2
d_pipe	0.0127	m
l_req	19.84821147	m

Length tubes required
 $Q=UA\Delta T$



Immersion cooling setup

Ice Required		LN2 Required		
Q*	3.3	Q*	3.3	kw
t	15	t	15	h
Q*	49.5	Q*	49.5	kWh
Lf_ice	334	Lf_LN2	199	kJ/kg
Lf_ice	0.093	Lf_LN2	0.0552	kWh/kg
m_ice_req	532.26	m_LN2	896.74	kg
minV_cubedice_req	1064.516129			L
minV_cubedice_req	281.2153548			gal
% loss, to ambient	50			%
V_cubedice_req	562.4307097			gal

Immersion fluid required

Low Temp Cooling - Design Details


Requirement: 3.3kW cooling, <0C

- Cooling capacity
 - 5.07 kW @ -2.5C
 - 3.58kW @ -12.2C
- Fluid
 - 50% ethylene glycol (antifreeze)
- Operation
 - ¾ NPT Inlet/Outlet
 - 208-240VAC input, 37A max current draw
 - Use 240V welding plug



Vacuum - Concept Selection & Design

- Vacuum requirements
 - Near-perfect vacuum applied to valves, <0.01bar
- Concept Selected: Vacuum line: roughing pump, hoses, manifold, solenoids
 - Enables high CFM (offset H2 leak rate), minimize leaks from vacuum pump
- Considered: vacuum chamber
 - No added utility: relief valves the only vac-rated hardware
 - Adds pump down time, valves spaced around wide area, seals interfere with Plant functions
- Hardware
 - 12 CFM roughing pump, 4E-5 bar minimum Pvac
 - Flow control: on/off via solenoid valves
 - Ball valves considered, but remote operation desired for safety
 - Manifold, fittings, hoses
 - NPT, pneumatic-rated liquid thread sealant (Loctite 545)
 - Sensing
 - Vacuum gauge




$$T = V/S * \ln(P1/P2)$$

Pump down time - hoses			Pump down time - chamber		
Length of piping	10	m	Volume of piping	1.00000	m^3
Diameter of piping	0.0127	m	Initial pressure	1	atm
Volume of piping	0.00127	m^3	Final pressure	1.00E-04	atm
Initial pressure	1	atm	Pump speed	12	CFM
Final pressure	1.00E-04	atm	Pump speed - leak rate	6	CFM
Pump speed	12	CFM	Pump Speed	0.0028	m3/s
Pump speed - leak rate	6	CFM	Pump down time	3252.606	s
Pump Speed	0.0028	m3/s			
Pump down time	4.120	s			

Vacuum - Build & Test

- Min vacuum pressure: 0.075 torr = 1E-4bar
- On/off via solenoids



Test results



Vacuum line

Subsystem - Power

Requirement: 60kW @ 200VDC, 10kW @ 120VDC

Starpath HQ Breaker

*5x
480VAC 3phase 25A*



DC Power Supplies

*4x 18kW 200VDC
1x 18kW 120VDC*



Plant

*72kW @ 200VDC
18kW @ 120VDC*

**notes:*

- *90kW total power*
- *Each 18kW supply can be fine-tuned between 0-600VDC*
- *Rental Jan 1 - Feb 28 for budget considerations*